

## Insulated Indoor Cover Installation Instructions - 1000, 3000, 4000 Series

1000 I.D. Cover

3000 I.D. Cover

4000 I.D. Cover



Insulated Indoor Cover shown in place over the inside of the unit.

The Indoor Sound Cover must be used with NCP condensing units, properly installed in the **WSD** series Wall Sleeve. (Models 1000-WSD-12, 3000-WSD-12 and 4000-WSD-12) only. **When properly installed, the indoor sound is substantially reduced. As well, thermal conductivity from the outdoors is eliminated.**



The Insulated Sound Cover will be supplied insulated, handles installed and assembled. To install, onto the unit, either the top or bottom will need to be removed, depending, on the exit point, of the tubing. (4 screws)



Inside view of sound cover showing sound barrier foil insulation.

**National Comfort Products®**

*A Division of National Refrigeration & Air Conditioning Products, Inc.*

539 Dunksferry Road • Bensalem, PA 19020 • (215) 244-1400 • **1-800-523-7138** • Fax: (215) 639-1674